

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2231

Dated: 30/03/2024

It is certified that an inspection team headed by Dr. Praveen Pandey

(Name of Officers with designation) from A.C.M.O. Ghazipur PHED

inspected the Crescent Convent School, Bye pass Road, Dildarnagan Ghazipur

(Name & Address of the school) on 30/03/24 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. R.W.T.L/SN/41/2324/00258 dated 29/03/2024


of Regional Water Analysis Lab. Jalandhar (PHED Lab) UNIS certified that

the Crescent Convent School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One Year

  
मुख्य चिकित्साधिकारी

Signature with Seal: गान्धीपुर

Name

Designation

Name & Address of the Office / Department :

Dr. Praveen Pandey

A.C.M.O. Ghazipur

Ghazipur

To The manager/Principal  
Crescent Convent School

(Name & Address of the Institution)

Bye pass Road, Dildarnagan  
Ghazipur

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

**\* TEST REPORT \***

Name & Address of Customer:		Customer Reference No.	No: 153/sk/62 Dated: 26/03/2024			
<b>CRESCENT CONVENT SCHOOL, BY-PASS ROAD, DILDARNAGAR, GHAZIPUR, U.P.</b>		Sample Submitted by	ABDUL KALAM KHAN			
		Date of Sample Receipt	26/03/2024			
		Analysis Starting Date	26/03/2024			
		Analysis completion Date	29/03/2024			
Discipline: Chemical Testing		Group: Water				
Test Report No.:	RWTL/SNG/2324/00258	Date of Issue:	05/02/2024			
Registration no.:	RWTL/SNG/2324/REG2324/00319	Condition of Sample:	Unsealed			
Source:	NA	Quantity/Type of Bottle:	1000ml / Amber Colored Glass Bottle			
Scheme:	NA	Location/Depth:	RO plant CRESCENT CONVENT SCHOOL, BY-PASS ROAD, DILDARNAGAR, GHAZIPUR, U.P./ NA			
Village:	Dildarnagar	Habitation:	NA			
Block:-	Dildarnagar	District:	Ghazipur			
Latitude:	NA	Longitude:	NA			
Sample Type: Treated Water						
Sr. No	Parameter	Result	As per 15-10500:2012 (2 <sup>nd</sup> Rev.)		Unit	Reference Method:
			Acceptable Limit	Permissible Limit		
1	pFI	7.75	6.5-8.5	No Relaxation		IS 3025 (Part 11-1993) Electrometric Method
2	Colour	01	5	15	Hazen	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable		IS3025 (Part 5-2018) (Second Revision)
4	TDS	280	500	"2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.19	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	12	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	120	200	600	mg/l	I63025 (Pan 21- 2019) EDTA Method
8	Calcium	27	75	200	mg/l	IS3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	13	30	100	m\$/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	88	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition:

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. \* Value not available or test not performed for this parameter.

Dr. Rajnish Yadav  
Quality Manager  
Authorized Signatory  
For, Regional Water Analysis,  
Laboratory Jan Nigam Varanasi – UP.

-----  
End of the Test Report